FIELD REPORT - Electrical

FIELD	REPORT - Electrical	GPD
TO: CC:	Frank John Di Stefano, ADG Cecilia Vaniman, MSU	
Date of Visit: Project:	Don Platisha, CMS 12/01/11 MSU Cooley Lab Renovation	ENGINEERS 524 1st Avenue South Great Falls, MT 59401 (406)452-9558 Fax (406)727-9720
GDP Job No.: Location: Contractor: Present at Site:	100104 Bozeman, MT Dick Anderson Construction, Liberty Electric Brad Kauffman (GPD), Don Platisha (CMS), Tim Tholt ((DAC) Grea
i resent at one.	Schermele (DAC), Eric Goroski (Liberty)	

Purpose of Visit:

The purpose of the visit was to walk the site to observe construction progress. I arrived at the site at approximately 3:00PM, talked with the contractors and then toured the building. I departed the site at 4:45PM.

Project Status:

- First through fourth floor conduit rough-in is close to complete.
- Third floor branch circuit wiring is about 75% complete.
- Most branch panels have been installed.
- Basement electrical room gear is mostly installed.
- Outdoor pad mount transformer and associated primary is installed.

Upcoming Work:

- Branch circuit conductor installation
- Generator installation
- Panelboard interior installation
- Device installation
- Light fixture installation

Deficiencies:

• There were no deficiencies noted.

END REPORT