

RFI103

Project: COOLEY LABORATORY RENOVATION  
Job: 3146 COOLEY LAB, PPA# 10-0023  
Customer: STOFMT MSU BOZEMAN  
Issued To: CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

POTENTIAL IMPACTS  
Cost Impact: No  
Schedule Impact: No

Attention: DONALD J. PLATISHA  
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: CONDENSER WATER SYSTEM PIPING Type: MECH  
Reference: 2/M3.2, Spec. 15704-2 2.1 Spec. Section:  
Attachments:

Description of Request

QUESTION:

The condenser water system is schedule 80 PVC for the underground and for the connection to the tanks. The specification calls for schedule 40 steel pipe for the rest of the system above ground. We would like to plumb the entire condenser water system out of schedule 80 PVC so we are not changing in and out of steel to schedule 80 PVC.

WILLIAMS PLUMBING

Respond By: 03/27/12 By: TIM THOLT

Response

Provide the piping as specified in the contract documents.

Signed: Don Platisha – per MSU/GPD discussion @ 3/21 mtg Date: 4/3/12

Proceed as Indicated: \_\_\_\_\_ Date: \_\_\_\_\_

Owner Authorized Representative/