

**RFI 105**

**Project:** COOLEY LABORATORY RENOVATION  
**Job:** 3146 COOLEY LAB, PPA# 10-0023  
**Customer:** STOFMT MSU BOZEMAN

POTENTIAL IMPACTS

**Cost Impact:** No  
**Schedule Impact:** No

**Issued To:** CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

**Attention:** DONALD J. PLATISHA  
**Phone/Fax:** 406 585-0611 / 406 585-2698

**Coordination copies to:**

**Item:** MECH INSUL AT FLOOR AND WALL PENETRATION **Type:** MECH  
**Reference:** 5/M3.4 **Spec. Section:**  
**Attachments:**

**Description of Request**

QUESTION:  
Drawing M3.4 detail 5 designates to conical the mechanical insulation at penetrations that have metal sleeves passing through the penetration. From past experience this is not asthetically appealing, thus we are requesting to have the ability to fully butt the insulation up to the metal sleeve as long as the fire caulking has been installed prior to installation of the insulation. We recommend this change as a large majority of the insulation is exposed to public view .

WILLIAMS PLUMBING

**Respond By:** 04/05/12 **By:** TIM THOLT

**Response**

Butting the insulation is acceptable. Note escutcheon requirements for exposed penetrations in Section 15080 and insure that the appearance of the finished termination is acceptable to the Owner.

**Signed:** Dave Broquist **Date:** 30 March, 2012

**Proceed as Indicated:** \_\_\_\_\_ **Date:** \_\_\_\_\_

Owner Authorized Representative