

RFI 111

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: GENERATOR PAD ON PRIMARY ELECTRICAL Type:
Reference: C1.2 Spec. Section:
Attachments: PICTURE

Description of Request

QUESTION:
The generator pad is scheduled to be placed on the electrical primary lines. Is this permissible or wanted? To avoid placing the generator pad on the elec primary lines the pad would have to move 5-6 feet north.

Respond By: 04/20/12 By: TIM THOLT

Response

Signed: _____ Date: _____

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative



Approximate SE
corner of generator

Primary power lines