

RFI 118

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS

Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: PENTHOUSE LIGHT SWITCHING

Type: ELECTRICAL

Reference: E2.5

Spec. Section:

Attachments:

Description of Request

QUESTION:
In the penthouse, 2 switches are shown in 3 locations. How would we like to switch the penthouse lights?
The C type fixture only has one switch leg. Do we want all the lights to come on at the same time or north
and south rows. Please advise.

LIBERTY ELECTRIC

Respond By: 05/01/12 **By:** TIM THOLT

Response

North and South rows switched separately from 3-way and 4-way switches.

Response by: Brad Kauffman (GPD) on 25 April, 2012.

Signed: _____ **Date:** _____

Proceed as Indicated: _____ **Date:** _____

Owner Authorized Representative