

**RFI 119**

**Project:** COOLEY LABORATORY RENOVATION  
**Job:** 3146 COOLEY LAB, PPA# 10-0023  
**Customer:** STOFMT MSU BOZEMAN  
  
**Issued To:** CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

**POTENTIAL IMPACTS**  
**Cost Impact:** No  
**Schedule Impact:** No

**Attention:** DONALD J. PLATISHA  
**Phone/Fax:** 406 585-0611 / 406 585-2698

**Coordination copies to:**

**Item:** SEALTITE FLEX CONDUIT IN LABS

**Type:** ELECTRICAL

**Reference:**

**Spec. Section:**

**Attachments:**

**Description of Request**

**QUESTION:**  
Is sealtite flexible conduit required in the labs i.e. utility panels, fire-smoke damper actuators, and fume hoods.  
  
LIBERTY ELECTRIC

**Respond By:** 05/11/12 **By:** TIM THOLT

**Response**

Seal-tite required for wet locations, exterior use, and when connecting to motors, vibrating equipment, and large equipment.  
Flexible metal conduit can be used for small equipment connections such as lab equipment and fire alarm smoke/fire dampers.

**Response by: Brad Kauffman (GPD) on 7 May, 2012.**

**Signed:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Proceed as Indicated:** \_\_\_\_\_ **Date:** \_\_\_\_\_

Owner Authorized Representative