

RFI 12

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: Underground Sanitary Sewer/ Storm Sewer
Reference:

Type:
Spec. Section:

Attachments:

Description of Request

Question:

The underground piping for the Sanitary Sewer and for Storm Sewer is called out as Cast Iron no hub. We would like to complete the underground in these two systems in Schedule 40 PVC, as we feel this is a better product for the application. The PVC would change to Cast at the concrete floor and there would be no visible PVC above ground.

Williams Plumbing

Respond By: 08/10/11 By: TIM THOLT

Response

The NIH Design Requirements Manual (DRM) does not allow PVC as a piping material. The specification is based on their approved materials. Since the construction grant is contingent upon DRM compliance, the piping must be installed as specified.

Response by: Dave Broquist, GPD Date: 5 August, 2011

Signed: _____ Date: _____

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative