

RFI 122

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS

Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: CABLE TRAY IN BASEMENT **Type:** ELECTRICAL
Reference: E2.0 **Spec. Section:**
Attachments:

Description of Request

QUESTION:
The bottom of the cable tray in the basement will be 7'-2" this will place the cable tray just above the door mullion and in those locations with a 4" door mullion in the center of the mullion. There is a location on the south side of the corridor by door 012 that the cable tray will be at an elevation of 6'- 11" to the bottom due to interference with fire piping and duct work (see attached picture).

RECOMMENDATION:
Eliminate the cable tray on the south side of the corridor or run the north/south 12" cable tray before door 012 to eliminate the cable tray running at an elevation of 6'-11".

Respond By: 05/28/12 **By:** TIM THOLT

Response

Signed: _____ **Date:** _____

Proceed as Indicated: _____ **Date:** _____

