

RFI 132A

**Project:** COOLEY LABORATORY RENOVATION  
**Job:** 3146 COOLEY LAB, PPA# 10-0023  
**Customer:** STOFMT MSU BOZEMAN  
  
**Issued To:** CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

POTENTIAL IMPACTS

**Cost Impact:** No  
**Schedule Impact:** No

**Attention:** DONALD J. PLATISHA  
**Phone/Fax:** 406 585-0611 / 406 585-2698

**Coordination copies to:**

**Item:** PIPE SIGNAGE LETTERING **Type:** MECH  
**Reference:** 15055-2.2-b **Spec. Section:**  
**Attachments:**

**Description of Request**

QUESTION:

*Is the following nomenclature acceptable for the pipe labeling:*

- HEATING WATER SUPPLY HEATING WATER RETURN
- CHILLED WATER SUPPLY CHILLED WATER RETURN
- INDUSTRIAL COLD WATER INDUSTRIAL HOT WATER
- INDUSTRIAL HOT WATER RECIRCULATION
- RO SUPPLY RO RETURN
- NATURAL GAS
- SANITARY SEWER
- SANITARY SEWER VENT DOMESTIC COLD WATER
- DOMESTIC HOT WATER DOMESTIC HOT WATER RECIRCULATION
- LABORATORY WASTE LABORATORY VENT CONDENSATE DRAIN
- HEAT RECOVERY SUPPLY HEAT RECOVERY RETURN
- STEAM SUPPLY STEAM CONDENSATE
- PUMPED STEAM CONDENSATE
- LABORATORY AIR
- CONTROL AIR

WILLIAMS PLUMBING

**Respond By:** 07/12/12 **By:** TIM THOLT

**Response**

- MSU does not want "glycol" included in the labels.
- The non-potable water needs to be labeled per code. This includes the lines and each outlet.

**Signed:** C.Vaniman **Date:** 7/18/2012

**Proceed as Indicated:** \_\_\_\_\_ **Date:** \_\_\_\_\_

