

RFI 136

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: Yes
Schedule Impact: No

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item Lab Air/Gas to Room 109 **Type:** Mech/Lab
Reference: M2.1.1 **Spec. Section:**15212
Attachments: None

QUESTION: **Description of Request**

On 1st floor the north side of the corridor and immediately East of 5 line (print M2.1.1) there is a service panel that does not show any Gas or Lab Air running to it Room 109. Does this unit require Gas and Air? And if so where should the utilities come from the piping to the East or West piping?

Respond By: 07/24/12 **By:** TIM THOLT

Response

The unit does require Gas and Air. They should be serviced from the nearest lines to the east.

Signed: DPlatisha **Date:** 7/24/2012

Proceed as Indicated: _____ **Date:** _____

Owner Authorized Representative