

RFI 137

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: Yes
Schedule Impact: No

Attention: DONALD J. PLATISHA **Coordination copies to:**
Phone/Fax: 406 585-0611 / 406 585-2698

Item Fume/Hood Supply Duct Height **Type:** Mech/Lab
Reference: M2.0.2 **Spec. Section:**11605/15841
Attachments: None

Description of Request

QUESTION:
In the Basement Room 012 the 30X18 supply duct will not allow the Fume Hood to be installed in that location. The obvious option would be to move the fume hood to the north 36".
Please Advise.

Respond By: 07/25/12 **By:** TIM THOLT

Response

Fume Hood can move north 31". Associated Casework under the fume hood will move north. 31" Knee space will need to be moved to be adjacent to the first 24" base cabinet. Epoxy top modified to accomodate the relocation.

Lower fumehood and associated casework 2 1/2" - revised response

See attached sketch

Signed: D Platisha **Date:** 7/25/2012

Proceed as Indicated: _____ **Date:** _____

Owner Authorized Representative