

RFI 138

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: Yes
Schedule Impact: No

Attention: DONALD J. PLATISHA **Coordination copies to:**
Phone/Fax: 406 585-0611 / 406 585-2698

Item: GLASSWASHER SOFT WATER LOOP **Type:** MECH
Reference: **Spec. Section:**
Attachments:

Description of Request

Question:
It has been discussed that provisions for a future soft water loop for the glass washer should be installed. No details on how many valves and how it should be piped has been provided. Is valving for future soft water loop for the glass washer still desirable?

Respond By: 08/20/12 **By:** TIM THOLT

Response

YES. A bypass loop will be required. A water softener will be added to the project by RFP. Both Autoclaves as well as the Glass washer will need to be serviced from the new water softener.

Signed: _____ D. Platisha **Date:** _____ 8/30/2012

Proceed as Indicated: _____ **Date:** _____

Owner Authorized Representative