

RFI 140

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698
Coordination copies to:

Item: SCULLERY SINK Type: SPECIALTY
Reference: SK-4, RM B008 Spec. Section:
Attachments:

Description of Request

After numerous shipping setbacks at the Elkay factory, we received SK-4 sink for room B008 this morning. We received model WSNF8230LR per specifications and per our submittal. This model is actually 78" wide not 72" wide as shown on the drawings. Is it permissible to decrease the size of the oven table to 61" to allow room for the scullery sink to fit? This allows room for the ovens and surrounds to be installed on top of the counter as planned.

ISEC

Respond By: 09/05/12 By: TIM THOLT

Response

Yes. I did go back to the submittal and noticed that the size was indeed 78"

Signed: Mark Osborn for Leading Edge Consulting Date: 8/28/12

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative