

RFI 143

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698
Coordination copies to:

Item: FIRE ALARM QUESTIONS Type: FIRE ALARM
Reference: Spec. Section:
Attachments:

Description of Request

QUESTION:
1) The main sprinkler riser feeding Cooley lab currently we believe should have a water bell and FDC connection, where is the location of this connection?
2) The flow and tamper switch setup located in Cooley lab was moved to the first floor ARC /Cooley corridor. The assumption is that this will need to be reconnected to the existing fire alarm panel that it was connected to originally is this correct or should it connect to the new Cooley fire alarm panel?

Respond By: 09/17/12 By: TIM THOLT

Response

response

Signed: Multiple Date: 9/10/2012

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative