

**RFI 18**

**Project:** COOLEY LABORATORY RENOVATION  
**Job:** 3146 COOLEY LAB, PPA# 10-0023  
**Customer:** STOFMT MSU BOZEMAN

POTENTIAL IMPACTS

**Cost Impact:** Yes  
**Schedule Impact:** No

**Issued To:** CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

**Attention:** DONALD J. PLATISHA  
**Phone/Fax:** 406 585-0611 / 406 585-2698

**Coordination copies to:**

**Item:** PLUMBING CONFLICT WITH BEAM FLOOR 4

**Type:** ARCH/STRUC

**Reference:** M2.4.1, A1.8, S2.4

**Spec. Section:**

**Attachments:**

**Description of Request**

**QUESTION:**

The concrete beam shown on S2.4 that runs between grid 3 and 4 along grid C.1 is directly below the south corridor wall shown on A1.8, this wall houses the drain and vent line for the sink at grid C and grid 3.8 which must run down from this location but is in conflict with the concrete beam.

**RECOMMENDATION:**

Fur out the wall eight inches to the south on the fourth floor to clear the beam and have room for the piping, this will move the sink and cabinetry south. On the third floor have an exposed vent and drain line at the ceiling and 90 it back into the corridor wall.

**Respond By:** 08/18/11 **By:** TIM THOLT

**Response**

**AS REVIEWED AND DISCUSSED ON SITE, THE RECOMMENDATION IS ACCEPTED AND THE WALL CAN BE FURRED THE MINIMUM NECESSARY FOR THE PIPING BUT NOT TO EXCEED 8 INCHES.**

**Signed:** F. J. di Stefano **Date:** 8-18-11

**Proceed as Indicated:** **Date:** \_\_\_\_\_  
Oner Authorized Representative