

RF1 2

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB
Customer: STOFMT STATE OF MONTANA

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: NEW METAL STAIR DETAILING
Reference: S2.4, 9/S3.1, 1/A8.2,

Type: ARCH/STRUC
Spec. Section:

Attachments: SKETCH 1 FROM GAMUT

Description of Request

For proper detailing of the metal stairs leading from the 4th floor to penthouse. The steel detailer has requested the attached information.

Respond By: 06/26/11 **By:** TIM THOLT

Response
via email --Mon 6/20/2011 9:22 AM

Two clarifications we need before we can respond.

One, They are showing a stair run from existing slab to existing landing. We don't have that condition. We are going from the existing 4F to the existing roof slab and the intermediate landing is new.


Two. They are asking for us to confirm the horizontal run between the two "existing" slabs. See above. We would not verify a filed dimension. That is for the detailer and DA.

Frank John di Stefano, AIA
Architect Design Group, pc

Signed: _____ **Date:** June 20, 2011

Proceed as Indicated: _____ **Date:** _____
Owner Authorized Representative

SDS/2 JOB: Cooley Lab Renovation



COOLEY LABORATORY RENOVATION
BOZEMAN, MT

REF DETAILS:
9/53.1, 1/A8.2

Plot Date: Jun 16 2011

SKETCH 1