

RFI 22

Project: COOLEY LABORATORY RENOVATION  
Job: 3146 COOLEY LAB, PPA# 10-0023  
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS  
Cost Impact: No  
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA  
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: SPARE CONDUITS PER RACEWAY

Type:

Reference: Note G per E2.4

Spec. Section:

Attachments:

Description of Request

QUESTION:

How many conduits are needed for future use or spares coming out of the 2-channel raceway in all the labs?  
Please advise the amount of conduits required per length of channel.

LIBERTY ELECTRIC

Respond By: 08/30/11 By: TIM THOLT

Response

The intent of this note was to never exceed (6) current carrying conductors in a single conduit, which is an NIH requirement. The requirement for (4) conduits per raceway came from the worst case scenario. There are some locations where (4) conduits would be more than is practical, so the note can be revised slightly for the shorter raceways.

For power conduits, provide (1) 3/4" conduit for every (6) current carrying conductors and then provide (1) empty (spare) 3/4" conduit, not to exceed (4) 3/4" conduits per raceway total. For example, if there is a raceway that shows (4) 120V circuits, or 8 current carrying conductors, this would equate to (3) total conduits. The first conduit would contain three circuits, the second conduit would contain one circuit, and the third conduit would be spare. In another example, if there is a raceway that shows (3) 120V circuits, or 6 current carrying conductors, this would equate to (2) total conduits. The first conduit would contain three circuits and the second conduit would be spare.

The requirement for (2) 1" conduits for data for each raceway shall remain.

Response by: Brad Kauffman (GPD) on 23 August, 2011.

Signed: \_\_\_\_\_

Date: \_\_\_\_\_

Proceed as Indicated:

Date: \_\_\_\_\_

Owner Authorized Representative