

RFI 32

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698
Coordination copies to:

Item: ELECTRICAL ROOM LAYOUT Type: ELECTRICAL
Reference: E2.0 Spec. Section:
Attachments:

Description of Request

QUESTION:
Is it permissible to switch the location of ATS-1 with MSDB from RFI 30 to accommodate existing utilities that we would like to stay longer and the new shear wall?

Field measurements were made and clearances will still be met if this occurred. There will be no cost increase for this movement. LIBERTY ELECTRIC

Respond By: 09/28/11 By: TIM THOLT

Response

- It is acceptable to relocate MSDB and ATS-1 as described.
- It should be noted that any work done in the existing electrical vault with live primary cabling is somewhat dangerous and the contractor may want to have the university kill power to the line while work is being done in that room, or at a minimum, the workers should be wearing protective clothing and gear approved for high voltages and fault levels. The cables need to be protected from damage as well.

Response by: Brad Kauffman (GPD) on 21 September, 2011.

Signed: _____ Date: _____

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative