

RFI 35

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS

Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: Electrical Panel Movement Type: ELECTRICAL
Reference: E2.1, E2.2, E2.3, E2.4, Spec. Section:
Attachments:

Description of Request

QUESTION:
Would it be permissible to relocate all of the A panels (normal power) on the north wall of each electrical room to the east wall, this will allow for a neater installation and more room to center the light in the room.

Respond By: 10/13/11 By: TIM THOLT

Response

Yes, relocating these panels is acceptable.

Response by: Brad Kauffman (GPD) on 7 October, 2011.

Signed: _____ Date: _____

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative