

RFI 38

Project: COOLEY LABORATORY RENOVATION  
Job: 3146 COOLEY LAB, PPA# 10-0023  
Customer: STOFMT MSU BOZEMAN  
Issued To: CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

POTENTIAL IMPACTS  
Cost Impact: No  
Schedule Impact: No

Attention: DONALD J. PLATISHA  
Phone/Fax: 406 585-0611 / 406 585-2698  
Coordination copies to:

Item: Underground Electrical Site Work Type: ELECTRICAL  
Reference: ES1.0 Spec. Section:  
Attachments:

Description of Request

QUESTION:  
Is it permissible to reroute all the underground conduit for the electrical site work including the cooling tower and generator (currently shown to enter the building midway point of the building) to enter the building at electrical room 006.  
LIBERTY ELECTRIC

Respond By: 10/03/11 By: TIM THOLT

Response

Yes, conduit can enter the building in 006.

Response by: Brad Kauffman (GPD) on 26 September, 2011.

Signed: \_\_\_\_\_ Date: \_\_\_\_\_

Proceed as Indicated: \_\_\_\_\_ Date: \_\_\_\_\_

Owner Authorized Representative