

RFI 44

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Attention: DONALD J. PLATISHA Coordination copies to:
Phone/Fax: 406 585-0611 / 406 585-2698

Item: RFP 4R CLARIFICATION Type: ARCH/STRUC
Reference: RFP 4R Spec. Section:
Attachments:

Description of Request

QUESTION:
1) Talking with the Spira-Lok manufacturer it is not typical to use asymmetrical Spira-Lok ties that will be tying into steel studs. Typically asymmetrical ties are used for going from mortar joint to concrete.
2) It is also not typical to use 10mm (3/8) ties for going through mortar joints as typical mortar joints are 3/8" and it can cause problems with spalling or cracking of the brick. 8mm or 5mm are available.

Respond By: By:

Response

PENDING RFP 4 FROM OWNER

Signed: DP Date: 10-20-11

Proceed as Indicated: Date:

Owner Authorized Representative