

RFI 51

Project: COOLEY LABORATORY RENOVATION  
Job: 3146 COOLEY LAB, PPA# 10-0023  
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS  
Cost Impact: Yes  
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA  
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: Receptacle Types Type: Electrical  
Reference: E4.0 Det. 1& 2 Spec. Section:

Attachments:

Description of Request

QUESTION:  
What type of Receptacle is required for all 2 pole devices. For example; 208v with neutral, twistlock device, or 208 volt only. Does any of the equipment require 120 and 208. Please advise.

Respond By: 11/01/11 By: TIM THOLT

Response

For all 208V-2P receptacles, provide twistlock type receptacles, NEMA L6-20R.

Per drawings, note that wire is #10 and includes a neutral, even though these are connected to 20 amp circuit breakers and receptacles with no neutral.

Response by: Brad Kauffman (GPD) on 3 November, 2011.

Signed: \_\_\_\_\_ Date: \_\_\_\_\_

Proceed as Indicated: \_\_\_\_\_ Date: \_\_\_\_\_

Owner Authorized Representative