

RFI 52

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS
Cost Impact: Yes
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: NO SUBSTRATE AT ROOF EAVES Type: ARCH/STRUC
Reference: A3.0, A6.0, A6.2, A0.6 Spec. Section:
Attachments:

Description of Request

QUESTION:
There is no substrate from the fascia of the eaves to the exterior the walls for the ice and water shield to attach to. The ice and water shield would attach to the top purlins but would not be supported between the purlins.

Respond By: 11/15/11 By: TIM THOLT

Response

RELOCATE DENSDECK FROM THE ROOF DECKING TO ALIGN WITH THE TOP OF ADJACENT RIGID INSULATION. SEE ATTACHED CLARIFICATION DRAWING CD-6.

Revised RESPONSE: 11/16/11 Progress Meeting:

Provide Continuous Polyiso insulation to support ice water shield from the fascia to the exterior walls.

Signed: _____ Date: _____

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative