

RFI 54

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: Air, Gas, and VAC in Laser Lab Type: ARCH/STRUC
Reference: QL1.0, M2.0.2, M2.0.3 Spec. Section:
Attachments:

Description of Request

QUESTION:
M2.0.2 and M2.0.3 do not show air, gas, or vac services to the mobile benches on grid line D/4,5, and 6. Do these benches require the air, gas, and vac turrets?

ISEC

Respond By: 11/18/11 By: TIM THOLT

Response

These benches do not require the Air, Gas or Vac connections.

Signed: Mark Osborn Date: 11/22/11

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative