

RFI 56

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Attention: DONALD J. PLATISHA Coordination copies to:
Phone/Fax: 406 585-0611 / 406 585-2698

Item: MUDRINGS ON DATA DROPS Type: ELECTRICAL
Reference: E0.1, E4.0 Spec. Section:
Attachments:

Description of Request

QUESTION:
What mudrings are required by MSU for all of their data drops? On the general notes of the electrical drawings it is shown to have a single gang. On sheet E4.0 it is shown to have a 2-gang mudring. Please verify which mudring is required for Cooley's data drops.

Liberty Electric

Respond By: 11/24/11 By: TIM THOLT

Response

MSU IT has confirmed that they would prefer a single gang mudring for all applications.

Signed: Cecilia R. Vaniman Date: 11-17-2011

Proceed as Indicated: Date:

Owner Authorized Representative