

RFI 60

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: VFD Testing Report Type: MECH
Reference: Spec 15180 Spec. Section:
Attachments:

Description of Request

QUESTION:

The VFD submittal review dated November 2, 2011 requests "Certification by the manufacturer that the VFD's have passed the factory 48-hour operational test". What are the specific requirements for the 48-hour test?

Tri-County

Respond By: 12/09/11 By: TIM THOLT

Response

Provide verification from the manufacturer that the drives have been factory run tested at rated load. A manufacturer's standard load test duration is acceptable.

Signed: Dave Broquist, GPD Date: 19 December, 2011

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative