

RFI 62

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS
Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: Wall Shelving Standards Type: ARCH/STRUC
Reference: 12345.2.11 Spec. Section:
Attachments:

Description of Request

QUESTION:
For wall shelving, confirm the following:

- 1. Single slot standard at the end of shelving run or where there is only a single shelf.
- 2. Double slot standards to be used where two shelves meet.

ISEC

Respond By: 12/16/11 By: TIM THOLT

Response

That is what my comment on the casework submittal was to mean, yes.

However, let's do this (the other option on the submittal) for your #1 comment above. Move the double slot at the end over so that the outside row of slots is used. This will clean up the wall a bit and leave an option for the Owner to use the standard K&V 185 shelf brackets if they want to.

This has the added benefit of only needing to stock and/or install one type of standard.

Signed: Mark Osborn – Leading Edge Consulting Date: 12/14/11

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative