

RFI 64

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOF MSU BOZEMAN
MT

POTENTIAL IMPACTS

Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: CIRCUITRY FOR UNIT HEATERS IN RFP 6B Type: ELEC

Reference: RFP 6B, CM-3 Spec. Section:

Attachments:

QUESTION:
The unit heaters shown in RFP 6B are shown to require 120V. No circuitry is currently shown. Please advise.

LIBERTY ELECTRIC

Respond By: 12/27/11 By: TIM THOLT

Response

RFP was sent prior to electrical wording. Please refer to newer version of the RFP.

Response by: Brad Kauffman (GPD) on 22 December, 2011.

Signed: _____ Date: _____

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative