

RFI 65

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS

Cost Impact: No
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

Attention:

Phone/Fax: DONALD J. PLATISHA
406 585-0611 / 406 585-2698

Coordination copies to:

Item: SUMP PUMP CIRCUITRY

Type: ELEC

Reference: E2.0, M2.0.3

Spec. Section:

Attachments:

Description of Request

QUESTION:

There is no circuitry shown for the new elevator sump pump in the elevator pit

LIBERTY ELECTRIC

Respond By: 12/27/11

By: TIM THOLT

Response

The pump is plug-in and there is a receptacle shown in the pit for this purpose. No additional circuit is required.

Response by: Brad Kauffman (GPD) on 22 December, 2011.

Signed: _____ Date: _____

Proceed as Indicated: _____ Date: _____

Owner Authorized Representative