

RFI 77

Project: COOLEY LABORATORY RENOVATION  
Job: 3146 COOLEY LAB, PPA# 10-0023  
Customer: STOFMT MSU BOZEMAN  
Issued To: CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

POTENTIAL IMPACTS  
Cost Impact: Yes  
Schedule Impact: No

Attention: DONALD J. PLATISHA  
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: REBAR AT ARC ADDITION Type: STRUCTURAL  
Reference: 12/S1.2, 10/S1.1 Spec. Section:  
Attachments:

Description of Request

QUESTION:  
On detail 12 on S1.2 there are two hook bars that start in the wall and terminate in the grade beam. No sizing or spacing for these hook bars are provided. Please provide sizing and spacing for this bar. Also no indication is given if this detail is a typical detail and should occur at all concrete walls that have an upper grade beam.

Respond By: 01/23/12 By: TIM THOLT

Response

Detail 12/S1.2 is typical for concrete walls that have an upper grade beam. Match hook size and spacing to wall vertical reinforcing. Lap bars per typical schedule on 2/S0.1.

Signed: Jerome Gannon Date: 1/17/12

Proceed as Indicated: Date:

Owner Authorized Representative