

RFI 89

Project: COOLEY LABORATORY RENOVATION  
Job: 3146 COOLEY LAB, PPA# 10-0023  
Customer: STOFMT MSU BOZEMAN

POTENTIAL IMPACTS  
Cost Impact: No  
Schedule Impact: No

Issued To: CONSTRUCTION MANAGEMENT SERV.  
P.O. BOX 7274  
BOZEMAN, MT 59715

Attention: DONALD J. PLATISHA  
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: LIGHTING IN ROOMS WITH FAN COILS Type: ELECTRICAL  
Reference: ELEC SHEETS Spec. Section:  
Attachments:

Description of Request

QUESTION:  
In the equipment rooms with a fan coil, the fan coil is preventing the light fixture to be centered in the room. The access doors on fan coil units open down so installing the lights below the fan coils is not an option. Where is the preferred placement of the light fixture in these areas?

LIBERTY ELECTRIC

Respond By: 02/21/12 By: TIM THOLT

Response

The light can be lowered and off centered as necessary for fan coil access.

Response by: Brad Kauffman (GPD) on 17 February, 2012.

Signed: \_\_\_\_\_ Date: \_\_\_\_\_

Proceed as Indicated: \_\_\_\_\_ Date: \_\_\_\_\_

Owner Authorized Representative