

RFI 93

Project: COOLEYLABORATORYRENOVATION
Job: 3146 COOLEYLAB,PPA#10-0023
Customer: STOFMT MSUBOZEMAN
IssuedTo: CONSTRUCTIONMANAGEMENTSERV.P.
O.BOX7274
BOZEMAN,MT59715

POTENTIALIMPACTS
CostImpact: No
ScheduleImpact:No

Attention: DONALDJ.PLATISHA **Coordinationcopiesto:**
Phone/Fax: 406585-0611/406585-2698

Item: CHANGINGKWALLTOJWALLFIRSTFLOOR **Type:** ARCH/STRUC
Reference: A1.3 **Spec.Section:**
Attachments: AttachedDrawing

Descriptionofrequest

QUESTION:
The wall located at gridline C.1 and 9 is shown to be typeK(see attached drawing) .Is it permissible to change this to a type J wall
To line up with wall located at grid line B and 9. Please advise.

RespondBy: 02/29/12 **By:** TIMTHOLT

Response

THE CHANGE TO A "J" WALL IS ACCEPTABLE.

Signed: F J DISTEFANO Date: 2-23-12

ProceedasIndicated: _____ Date: _____

OwnerAuthori
zedRepresent
ative

