

RFI 97

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV.
P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS
Cost Impact: Yes
Schedule Impact: No

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: SEALING WINDOW SILLS **Type:** ARCH/STRUC
Reference: 8/A8.1 **Spec. Section:**
Attachments: 1 DRAWING

Description of Request

QUESTION:
Due to the existing field conditions it appears it will be difficult to get a good seal at the windows. With the Building being under negative pressure it is our opinion that a good seal at this location is imperative. We would propose using the attached detail for sealing of the sills.
Please verify this is acceptable.

Respond By: 03/15/12 **By:** TIM THOLT

Response

We confirm our acceptance of this approach.

Signed: Frank John di Stefano

Date: 3-19-12

Proceed as Indicated: _____

Date: _____

