

RFI 98

Project: COOLEY LABORATORY RENOVATION
Job: 3146 COOLEY LAB, PPA# 10-0023
Customer: STOFMT MSU BOZEMAN
Issued To: CONSTRUCTION MANAGEMENT SERV. P.O. BOX 7274
BOZEMAN, MT 59715

POTENTIAL IMPACTS

Cost Impact: No
Schedule Impact: No

Attention: DONALD J. PLATISHA
Phone/Fax: 406 585-0611 / 406 585-2698

Coordination copies to:

Item: BEAM STIFFENERS AT ARC JOIST
Reference: 9/S1.2
Attachments: 1 PICTURE

Type:

Spec. Section:

Description of Request

QUESTION:
The layout for beam stiffeners to support the existing bar joists was improperly layed out they are off 4" to the south at all joists (see attached picture). Are the web stiffeners as currently placed acceptable ? If the current location of the web stiffeners are not acceptable. Is there a solution to add web stiffeners to only the east side of the beam as shown in the picture the CMU wall is already built making the backside of this beam inaccessible.

Respond By: 03/16/12 By: TIM THOLT

Response

The 4" offset of the web stiffeners will be acceptable.

From the photo, it appears that the back side of the W10 is not accessible. Please confirm that the bolts through the C4 and the bent plate can be installed.

Jerome Gannon 3/16/12

Signed: _____

Date: _____

Proceed as Indicated: _____

Date: _____

Owner Authorized Representative

