

REQUEST FOR PROPOSAL

Project Title: Cooley Laboratory Renovation
Location: Montana State University

PPA No.: 10-0023
RFP No.: 46
Date: 05/01/12

To: Dick Anderson Construction
4498 Jackrabbit Lane
Bozeman, MT 59718

Attention: Platisha

From: Cecilia Vaniman, Project Manager
Cooley Lab Renovation
Montana State University

Attention: _____

In order to expedite the Work and avoid or minimize delays in the Work the following proposal is requested. Please return a response by: 05/07/12 Date Sent: 05/01/12 Date Received: _____

RFP Remove Brick Sill and Replace with Concrete Sill

Reference Drawings: Detail 4 on A5.0

Reference Specifications: 03300 Concrete.

Remove Brick Sill and Brick course under Brick Sill at the Southwest & S.E. Curtain Walls. Replace Sill with Concrete Sill. Contractor can use a Cast-in-Place method or A pre-cast concrete sill.


Sill to be install Drilled and Epoxy 3” embeds #4 bar 16” O.C. All joints to be caulked/grouted or flashed for a watertight installation around the perimeter Of the New Concrete sill. See attachments for clarifications.

Attachments: RFP46


- Photo existing condition**
- Revised Detail**

This RFP is for pricing purposes only. The contractor shall not proceed with the scope of work described within until pricing is approved by the owner in writing.

Distribution: Owner Architect Engineer
 Agency Contractor Other



REMOVE EXISTING BRICK BELOW CURTAIN WALL. REPLACE WITH ;
CONTRACTOR OPTION
 OPTION A - PRECAST SILL
 OPTION B - CAST-IN-PLACE SILL



4 CURTAIN WALL SILL
 3"=1'-0"



REMOVE BRICK SILL AND BOTTOM COURSE FROM CONCRETE FOUNDATION