

**REQUEST FOR PROPOSAL**

Project Title: Cooley Laboratory Renovation  
Location: Montana State University

PPA No.: 10-0023  
RFP No.: 73  
Date: October 3, 2012

To: Dick Anderson Construction  
4498 Jackrabbit Lane  
Bozeman, MT 59718

Attention: Platisha

From: Cecilia Vaniman, Project Manager  
Cooley Lab Renovation  
Montana State University

Attention: \_\_\_\_\_

In order to expedite the Work and avoid or minimize delays in the Work the following information is requested. Please return a response by: 10/10/2012 Date Sent: 10/03/2012  
Date Received: \_\_\_\_\_

Proposal Requested:

**PROVIDE Light Fixture Switch & GFCI Receptacle @ the top of the elevator shaft**

Scope of work includes; Division 16

Provide type 'C' light fixture and light switch wired at 120V and GFI receptacle on same circuit (similar to configuration in elevator pit). Locate at top of elevator shaft (coordinate exact location with owner's representative on-site). Connect to nearest convenience receptacle circuit in penthouse on other side of elevator shaft.

**This RFP is for pricing purposes only. The contractor shall not proceed with the scope of work described within until pricing is approved by the owner in writing.**

Distribution:  Owner  Architect  Engineer  
 Agency  Contractor  Other