



REQUEST FOR PROPOSAL

Project Title: Cooley Laboratory Renovation
Location: Montana State University

PPA No.: 10-0023
RFP No.: 74r
Date: October 5, 2012

To: Dick Anderson Construction
4498 Jackrabbit Lane
Bozeman, MT 59718

Attention: Platisha

From: Cecilia Vaniman, Project Manager
Cooley Lab Renovation
Montana State University

Attention:

In order to expedite the Work and avoid or minimize delays in the Work the following information is requested. Please return a response by: 10/31/2012 Date Sent: 10/25//2012 Date Received:

Proposal Requested:

PROVIDE 1/2" COMPRESSED AIR TO LASER TABLES


Scope of work includes; 15060 Pipe & Pipe Fittings 15080 Piping Specialties 15100 Valves 15212 Laboratory Air & Gas Piping

- ADD 1/2" COMPRESSED AIR AS DEPICTED ON DIAGRAMS (4) 5 LOCATION DROPS
INSTALL 1/2" ISOLATION VALVES 1 @ CORRIDOR AND 1 @ EACH DROP (4) 5 DROPS
PROVIDE ALL HANGERS PER PROJECT REQUIREMENTS.

SEE ATTACHED PIPE ROUTING DIAGRAM PHOTOS.

This RFP is for pricing purposes only. The contractor shall not proceed with the scope of work described within until pricing is approved by the owner in writing.

Distribution: [] Owner [] Agency [x] Architect [x] Contractor [] Engineer [] Other






TYPICAL PIPING
& VALVE
LOCATION AT
LASER TABLES



DOOR 05

USE THIS PENETRATION
FOR LAB AIR



NATURAL GAS

REVERSE OSMOSIS
HOT WATER
COLD WATER

LAB 315

CONNECTION POINT

VALVE