



REQUEST FOR PROPOSAL

Project Title: Cooley Laboratory Renovation
Location: Montana State University

PPA No.: 10-0023
RFP No.: 8
Date: 9/21/11

To: Dick Anderson Construction
4498 Jackrabbit Lane
Bozeman, MT 59718

Attention: Platisha

From: Cecilia Vaniman, Project Manager
Cooley Lab Renovation
Montana State University

Attention:

In order to expedite the Work and avoid or minimize delays in the Work the following proposal is requested. Please return a response by: 09/28/2011 Date Sent: 09/21/2011 Date Received:

Proposal Requested:

Pipe Tees for Flushing R-O System

Reference Drawings: M2.0.2, M2.1.1, M2.2.1, M2.3.1 and M2.4.1

Reference Specifications: N/A

On all floors, at the location that the PVC reverse osmosis piping leaves the vertical pipe chase and just on the "floor" side of the isolation valves for each floor, install a 3/4" tee with a true union ball valve to allow flushing of all piping on a single floor while isolated from the mains. Change the three-way diverting valves and crossover pipe on each floor to two way isolation valves and delete the crossover piping.

This RFP is for pricing purposes only. The contractor shall not proceed with the scope of work described within until pricing is approved by the owner in writing.

Distribution: [] Owner [] Agency [x] Architect [x] Contractor [] Engineer [] Other