

**REQUEST FOR PROPOSAL**

Project Title: Cooley Laboratory Renovation  
Location: Montana State University

PPA No.: 10-0023  
RFP No.: 94  
Date: January 24, 2013

To: Dick Anderson Construction  
4498 Jackrabbit Lane  
Bozeman, MT 59718

Attention: Platisha

From: Cecilia Vaniman, Project Manager  
Cooley Lab Renovation  
Montana State University

Attention: \_\_\_\_\_

---

In order to expedite the Work and avoid or minimize delays in the Work the following information is requested. Please return a response by: 01/31/2013 Date Sent: 01/25/2013  
Date Received: \_\_\_\_\_

Proposal Requested:

**REVISE ELECTRICAL POWER AT LASER TABLES**

Scope of work includes; Division 16

Remove existing plugmold strips from west and east sides of laser tables and return to owner (6 total locations). Provide new *surface box (finish to match existing surface boxes)* at each location with (1) Nema 5-20R duplex receptacle in each. Re-use existing cord with twistlock plug from removed plugmold. The west end receptacles are on emergency power and need to be red in color (3 total) and the east end receptacles are on commercial power and need to be gray in color (3 total). Mount new boxes on shelf, where existing plugmold was mounted, centered on shelf.


SEE ATTACHED Sheets RFP94-1

**This RFP is for pricing purposes only. The contractor shall not proceed with the scope of work described within until pricing is approved by the owner in writing.**

---

Distribution:  Owner  Architect  Engineer  
 Agency  Contractor  Other





1. REMOVE STRIP PLUGMOLD
2. REPLACE WITH 20AMP DUPLEX RECEPT.
3. PLACE ON EMERGENCY CIRCUIT

1. REMOVE STRIP PLUGMOLD
2. REPLACE WITH 20AMP DUPLEX RECEPTACLE

N
2
**BASEMENT FLOOR  
POWER & SPECIAL SYSTEMS REMODEL PLAN**  
 SCALE: 1/8"=1'-0"